





220-240V ~ 50Hz

MAINS SUPPLY



APPROVED
18/6/2025
ISSUE 1

Q.C



TIME	RANGE	LUX
10(+/-5) Sec 5(+/-1) Min	12M max	10(+/-10Lux)


HOW TO CHANGE INTO MANUAL :

During AUTO MODE, by switching the ON/OFF main switch for 2 times within 3seconds then switch on, the PIR detector will automatically change into MANUAL MODE from AUTO MODE. In MANUAL MODE, the Lamp(s) will remain ON , in MANUAL MODE the PIR detector not affected

During MANUAL MODE or AUTO MODE, by switching off the ON/OFF main switch over 6 seconds and then on again, the PIR detector will reset to WARM-UP periods. Please note: the periods of "WARM-UP" maybe be shorter than 1 minute.



Max 100W



Max 30W



Max 15W